

[ISPTMT176305NOV1208] [0811]

[INQ]

[20081030]

PERMIT TYPE: [BD] PERMIT NUMBER: [0604297] [0930] [000003044336]

ADDRESS: [0123][ ][ ] [VIVIAN ] [ST ] JURISDICTION: CI

DESCRIP: [ ]

BY	DATE	TIME	TP	MC	AP	FEE	----- COMMENTS -----
[ JWR	101708	1500	FN		DA		5-INTERIOR WORK INCOMPLETE ]
[							-NOTE: PARTIAL INSPECTION ONLY ]
[ DRC	102808	1000	SC		NA		- IN CONFERENCE W/GENE BRADHAM, ROY ]
[							BROCKWELL, DENNIS RITCHIE, DAVID ]
[							COWARD, AND PHIL NELSON (ARCHITECT OF ]
[							PROJECT) ]
[							- DETERMINED CONDITIONAL OCCUPANCY - ]
[							"NOT OPEN TO PUBLIC" MAY BE ALLOWED ]
[							SO THAT CONTRACTOR HAS TIME TO MAKE ]
[							CORRECTIONS ON GUARDS WHERE NOT AT 42" ]
[							AS REQ'D. ALL OTHER ISSUES FOR ]
[							CONDITIONAL OCCUPANCY MUST BE ]
[							SATISFIED AND APPROVED. ]
[							- GUARD CORRECTION TO BE COMPLETE PRIOR ]
[							PUBLIC OPENING 11-30-08. ]

[MORE INSPECTIONS, MOVE CURSOR TO END AND TRANSMIT ][@]

14:17:12:03 INQUIRY REQUEST

0.00

[ISPTMT176305NOV1208] [0811]

[INQ]

[20081031]

PERMIT TYPE: [BD] PERMIT NUMBER: [0604297] [1247] [000003044370]

ADDRESS: [0123] [ ] [ ] [VIVIAN ] [ST ] JURISDICTION: CI

DESCRIP: [ ]

BY	DATE	TIME	TP	MC	AP	FEE	COMMENTS
[ JWR	103008	0930	FN		DA		-PARTIAL INSPECTIONS ONLY: MET WITH DEPT ] SUPERVISORS, ARCHITECT & CONTRACTOR ] ABOUT THE FOLLOWING: REQUIREMENTS FOR & ] SPACING OK-FRONT EXTERIOR STAIR HANDRAIL ] -CERTIFICATION ON RAMPS INSIDE & OUT RE: ] HANDRAIL REQUIREMENTS TEMP STAIR WELL ] GUARD PROPOSAL, EXIT AND DIRECTIONAL ] SIGNAGE, AUDITORIUM HANDICAP SEATING ] ISSUES, SLOPE ON WARPED SECTION OF FLOOR ] AT ORCHESTRA LEVEL, STAIR ISSUES ON ] EXTERIOR PLAZA ]
[ JWR	103108	1247	FN		DA		-PARTIAL INSPECTION: REMOVE EXIT SIGN ] BETWEEN BASEMENT & OFFICE AREA; ADD CURB ] ON SIDE OF RAMP IN BASEMENT; ADD ] HANDRAILS AT FRONT STEPS AT CENTER-LINE ]

[MORE INSPECTIONS, MOVE CURSOR TO END AND TRANSMIT ][@]  
14:17:19:62 INQUIRY REQUEST 0.00

[ISPTMT176305NOV1208] [0811]

[INQ]

[20081104]

PERMIT TYPE: [BD] PERMIT NUMBER: [0604297] [1401] [000003044523]

ADDRESS: [0123][ ][ ] [VIVIAN ] [ST ] JURISDICTION: CI

DESCRIP: [ ]

BY	DATE	TIME	TP	MC	AP	FEE	COMMENTS
[ JWR	103108	1247	FN		DA		OR DOOR AND CENTER OF RUN ON END. NOTE: ]
[							QUESTION GUARDRAIL HEIGHT ON SPIRAL ]
[							STAIRS AND UPPER LEVEL PLATFORMS; REMOVE ]
[							PLYWOOD SCRAP ON SIDE TOWER CEILINGS. ]
[ JWR	110408	1401	FN		DA		PLACEMENT/SPACING OF EXTERIOR MONUMENTAL ]
[							STAIR HANDRAILS -2) CERTIFICATION OF RAMP ]
[							AND WALK SLOPES INSIDE/OUTSIDE -3) FLOOR ]
[							DROPOFF BETWEEN TOP OF INTERIOR STAIR ]
[							& SLOPED WALKWAY IN LOBBY -4) GUARDRAILS ]
[							IN STAIR WELLS (TEMPORARY FIX) -5) CURB AT ]
[							BASEMENT TO OFFICE CORRIDOR RAMP-REMOVE ]
[							EXIT SIGN AT OFFICE AREA DOOR (BASEMENT ]
[							SIDE) -6) HANDICAP SEATING-DISTRIBUTION & ]
[							REMOVABLE SEAT SPACES-7) ACCESSIBLE ROUTE ]
[							SIGNAGE TO & FROM AUDITORIUM -8) SIGNAGE ]

[MORE INSPECTIONS, MOVE CURSOR TO END AND TRANSMIT ][@]

14:17:27:85 INQUIRY REQUEST

0.00

[ISPTMT176305NOV1208] [0811]

[INQ]

[20081105]

PERMIT TYPE: [BD] PERMIT NUMBER: [0604297] [1159] [000003044501]

ADDRESS: [0123][ ][ ] [VIVIAN ] [ST ] JURISDICTION: CI

DESCRIP: [ ]

BY	DATE	TIME	TP	MC	AP	FEE	COMMENTS
[ JWR	110408	1401	FN		DA		-PERMANENT ROOMS-EXIT TACTILE, STAIR ]
[							AND LEVEL OF DISCHARGE, BOX OFFICE:ALSO, ]
[							INSP.CONT.-9)WARPED FLOOR SECTION AT ]
[							EITHER SIDE OF AUDITORIUM ORCHESTRA LVL ]
[							10)EXTERIOR STAIR--LEFT SIDE(MANGUM ST) ]
[							PLAZA -11)FENCE AROUND MECH. EQUIP ON ]
[							WEST SIDE OF BLDG.-12)EMERGENCY LIGHTING ]
[							TEST CERTIFICATION-13)GUARDRAIL HEIGHT: ]
[							SPIRAL STAIRS & WORKING LEVEL PLATFORMS ]
[							-14)REMOVE PLYWOOD SCRAP FROM UPPER ]
[							LEVEL CEILING RIGHT OF STAGE ]
[							15)CERTIFICATION ON CURTAIN FABRIC, ]
[							CERTIFICATION FROM STRUCTURAL ENG. THIRD ]
[							PARTY ENG; FDN SURVEY, PLANNING SIGN-OFF ]
[ JWR	110508	1159	SC		NA		-QUESTION CONCERNING GUARDRAIL HEIGHTS ]
[MORE INSPECTIONS, MOVE CURSOR TO END AND TRANSMIT ][@]							
14:17:36:25	INQUIRY REQUEST					0.00	

[ISPTMT176305NOV1208] [0811]

[INQ]

[00000000]

PERMIT TYPE: [BD] PERMIT NUMBER: [0604297] [0000] [000000000000]

ADDRESS: [0123][ ][ ][VIVIAN ] [ST ] JURISDICTION: CI

DESCRIP: [ ]

BY	DATE	TIME	TP	MC	AP	FEE	COMMENTS
JWR	110508	1159	SC		NA		ON WORKING LEVELS, FLY GALLERY & GRIDIRON
							RESOLVED PER CODE SECTIONS 410.5.4 AND
							1012.1 EXCEPTION 35 REGULAR HANDRAIL
							HEIGHT OK ON STAIRS AND GUARDRAILS NOT
							REQUIRED AT ALL WORKING LEVELS.

[THERE ARE NO MORE INSPECTION RECORDS TO DISPLAY ] [ @ ]

14:17:43:84 INQUIRY REQUEST 0.00